

## CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY067-Bldg 2 Date of Visit: 2-4-18

Contractor Personnel on Site:

1. <u>Patrick Brown</u>	4. _____
2. _____	5. _____
3. _____	6. _____

Service Call Number

CSS# 17184 WO# 2514

Description of Repairs

Replaced Wild Circulating Pump in motor Pool Bldg 2

---

---

---

---

---

## CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Brown Date: 2-4-18

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Douglas Bushlo Date: 2-4-18

Signed: 

E-Mail: Douglas.Bushlo.DR@mail.mil

max

3 2 1

eco

W

110 85 60

1~115V/60Hz  
I max 0,92A

CSA enclosure 2  
IMPEDANCE  
PROTECTED  
WORKING  
PRESSURE  
140 PSI MAX.  
Max. water  
temperature  
230°F (110°C)  
Use copper  
conductors only  
DO NOT RUN PUMP DRY

**Class F -9µf**

Do not install with  
motor above or  
below pump body

For indoor use only  
Employer unique-  
ment à l'intérieur

**WARNING:**  
To reduce the risk of  
electric shock see  
instruction manual  
for proper installation

Nr. 4171560 /16w40  
Typ Star S 21 RFC

Made by WILO  
in France

UL us  
LISTED WATER CIRCULATING PUMP  
24AC

**WILO**

LISTED WATER CIRCULATING PUMP

24AC

**WILO**