

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY039 - Bldg 1 Date of Visit: 2-14-19

Contractor Personnel on Site:

- | | |
|-------------------------|----------|
| 1. <u>Patrick Brown</u> | 4. _____ |
| 2. _____ | 5. _____ |
| 3. _____ | 6. _____ |

Service Call Number

CSS# 17187 WO# 2504

Description of Repairs

Removed old corroded and leaking pipes and
Replaced them with new 1" copper pipe & fittings, connected
to a dielectric union screwed to black pipe with a new
3/4" boiler drain valve at the bottom

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Brown Date: 2-14-19

Signed: _____

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Doug Rushlo Date: 02-14-19

Signed: _____

E-Mail: douglas.rushlo@usmc.mil





30UK64
Water Drain Valve 3/4
in. NPT x 9/16
1/2 in. NPT x 9/16