

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: Ny035 bldg 1 Date of Visit: 5/31/19

Contractor Personnel on Site:

- | | |
|---------------------------------|----------|
| 1. <u>Hyde-Stone Mechanical</u> | 4. _____ |
| 2. <u>Derek Perry</u> | 5. _____ |
| 3. <u>Jim Smith</u> | 6. _____ |

Service Call Number

CSS# 17331 WO# 3380


Description of Repairs

Removed old burner assembly and gas valves on asset#
9824 and replaced with new burner assembly and gas
valves, started up and tested unit for proper operation

CERTIFICATION OF WORK

To be signed by the Contractor:


Print Name: Derek Perry Date: 5/31/19

Signed: 


To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Doug Rushlo AFOS Date: 5/31/19

Signed: 

E-Mail: _____



old burner assembly asset# 9824 boiler



new burner installed