

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY035-Bldg 1 Date of Visit: 1-22-19 / ~~2-1-19~~ 2-1-19

Contractor Personnel on Site:

- | | |
|----------|----------|
| 1. _____ | 4. _____ |
| 2. _____ | 5. _____ |
| 3. _____ | 6. _____ |

Service Call Number

CSS# 17337 WO# 2509

Description of Repairs

Replaced Water Reducing Valve, and pump #4 Asset # 9843

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrice Brown Date: 2-1-19

Signed: _____

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Douglas Rushko Date: 2/1/19

Signed: _____

E-Mail: douglas.rushko@etrg.mil.mil

Asset# 9843 HWP - 4

WARNING
NON-SUBMERSIBLE PUMP
THIS PUMP HAS NOT BEEN INVESTIGATED
FOR USE IN SWIMMING POOL OR MARINE AREAS
RISK OF ELECTRIC SHOCK
TO REDUCE RISK OF ELECTRIC SHOCK, SEE
INSTRUCTION MANUAL FOR PROPER INSTALLATION.
THERMALLY PROTECTED
FOR SUPPLY CONNECTIONS USE COPPER
CONDUCTORS WITH INSULATION
ACCEPTABLE FOR AT LEAST 90 °C (194 °F).





Asset# 9843 HWP - 4

96. 41 07 74 (1 ph.)

WARNING

NON SUBMERSIBLE PUMP
THIS PUMP HAS NOT BEEN INVESTIGATED
FOR USE IN SWIMMING POOL OR MARINE AREAS
RISK OF ELECTRIC SHOCK
TO REDUCE RISK OF ELECTRIC SHOCK, SEE
INSTRUCTION MANUAL FOR PROPER INSTALLATION.
THERMALLY PROTECTED
FOR SUPPLY CONNECTIONS USE COPPER
CONDUCTORS WITH INSULATION
ACCEPTABLE FOR AT LEAST 90°C (194°F).

