

Additional Funding Request

NY035	CSS# 17337 WO# 2509 Asset# 9843																			
Description of Repairs	Labor and materials to replace bad reducing valve and circulating pump.																			
Diagnosis: Initial Work Order	BOILERS ARE ON BUT NOT HEATING BLDG NEED TO GET THIS DONE WE ARE TRYING TO HEAT WITH ELEC HEATER TO HOLD BLDG																			
Diagnostic Fee	\$160 TW Labor 2 hours @ \$ 80																			
Additional Labor Cost to Perform Repairs	\$640 TW Labor 8 hours @ \$ 80																			
Additional Material Cost to Perform Repairs	<p>\$1,335.41</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 60%;">Circ Pump Versaflo UPS32-80/2 - GRU96402709</td> <td style="width: 15%; text-align: center;">1</td> <td style="width: 15%; text-align: center;">\$951.91</td> <td style="width: 10%; text-align: center;">\$951.91</td> </tr> <tr> <td>Flange - GRU519604</td> <td style="text-align: center;">1</td> <td style="text-align: center;">\$19.01</td> <td style="text-align: center;">\$19.01</td> </tr> <tr> <td>Various Misc Materials (see attached Grainger detail)</td> <td style="text-align: center;">1</td> <td style="text-align: center;">\$273.73</td> <td style="text-align: center;">\$273.73</td> </tr> <tr> <td>Sales Tax</td> <td></td> <td></td> <td style="text-align: center;">\$90.76</td> </tr> </table>				Circ Pump Versaflo UPS32-80/2 - GRU96402709	1	\$951.91	\$951.91	Flange - GRU519604	1	\$19.01	\$19.01	Various Misc Materials (see attached Grainger detail)	1	\$273.73	\$273.73	Sales Tax			\$90.76
Circ Pump Versaflo UPS32-80/2 - GRU96402709	1	\$951.91	\$951.91																	
Flange - GRU519604	1	\$19.01	\$19.01																	
Various Misc Materials (see attached Grainger detail)	1	\$273.73	\$273.73																	
Sales Tax			\$90.76																	
Total Cost of Repair	\$2,135.41																			



WORK ESTIMATE

CSS #:

17337

Work Order #:

2509

Emergency

Urgent

Routine

Company Name:	Tidewater, Inc.	Facility ID:	NY035
Contractor POC:	Adam Colopy		
Telephone No:	740-819-6207	Building/Location; (e.g., Classroom/Room #)	Boiler Room
E-Mail Address:	adam.colopy@tideh2o.net		
Assigned Technician(s):	Patrick Brown		

DESCRIPTION of WORK and EXPLANATION for REPAIRS or REPLACEMENT

Labor and materials to replace bad reducing valve and circulating pump.

LABOR/MATERIAL		MATERIAL/ SUB UNIT DOLLAR AMOUNT	LBR/HR \$80	LINE ITEM TOTAL DOLLAR AMOUNT
ITEM	QUANTITY			
Labor			8	\$640.00
Circ Pump Versaflo UPS32-80/2 - GRU96402709	1	\$951.91		\$951.91
Flange - GRU519604	1	\$19.01		\$19.01
Various Misc Materials (see attached Grainger detail)	1	\$273.73		\$273.73
Sales Tax				\$90.76
Diagnostic Labor			2	\$160.00
SUB-TOTAL COSTS:		Materials Total	\$1,335.41	Labor \$800.00
		TOTAL		\$2,135.41

F.W. Webb Company
6792 Townline Road
Syracuse, NY 13211
TEL# (315-476-9322)
FAX# (315-472-4139)

Quote
Number
01/22/19
61767882

To:

SYRACUSE PREFERRED CUSTOMER
CASH, CHECK OR CREDIT CARD
6792 TOWNLINe ROAD
SYRACUSE NY 13211

SYRACUSE PREFERRED CUSTOMER
CASH, CHECK OR CREDIT CARD
6792 TOWNLINe ROAD
SYRACUSE NY 13211

(315-476-9322)

Cust #	Customer Po#	Rel#	Writer	Date Req
52404	TIDEWATER INC.		BTW	01/22/19

PAGE 1 OF 1

Quoted By: BRIAN WOLFORD

Quantity	Description	Net Price	Exten	Ln#
1	* CIRC PMP VERSAFLO UPS32-80/2 1/2HP 11 GRU96402708 (222368)	793.260	793.26	(1)
1	* FLG SBRUTE 1-1/2" NPT CI GRU519604 (222396)	15.840	15.84	(2)
		Sub Total:		809.10
		Freight:		
		Handling:		
		Total:		809.10

*** NUMBER OF DAYS QUOTE VALID IS 15 ***

PLEASE REFERENCE QUOTE # 61767882 FOR INQUIRIES OR ORDER OF ABOVE MATERIAL

To:

TIDEWATER INC
6625 SELNICK DR #A
ELKRIDGE MD 21075-6220

Information

Date 01/22/2019
 Customer Account Number 885295220
 Grainger Quote Number 42494528
 Customer Job Number
 Contract Number
 Grainger Representative Brittany Garza
 Phone Number
 Fax Number
 Email
 Grainger Tax ID 36-1150280

Item	Description Manufacturer Name & Model	Cat. Pg. #	Qty	\$ Quote	Ext. Price	Start Date	Exp. Date
20JN45	Gauge,Pressure,0 to 100 psi,2-1/2 in. WINTERS PFQ804LF Country of Origin: China	577	4	35.00	140.00	01/22/2019	03/01/2019
11X171	Black Pipe Nipple,Threaded,2x7 In BECK 330039009 Country of Origin: USA	2766	1	10.44	10.44	01/22/2019	02/21/2019
36H236	Hex Cap Screw,1"-8,2"Steel,PK5 FABORY U01000.100.0200 Country of Origin: Multiple	2056	1	13.00	13.00	01/22/2019	02/21/2019
1LLZ8	Black Pipe Nipple,Threaded,3/8x2-1/2 In GRAINGER APPROVED 1LLZ8 Country of Origin: Multiple	2769	1	4.00	4.00	01/22/2019	03/01/2019
1LMA3	Black Pipe Nipple,Threaded,3/8x4-1/2 In GRAINGER APPROVED 1LMA3 Country of Origin: Multiple	2769	1	5.73	5.73	01/22/2019	03/01/2019
1LLX3	Black Pipe Nipple,Threaded,1/4x2-1/2 In GRAINGER APPROVED 1LLX3 Country of Origin: Multiple	2769	1	3.50	3.50	01/22/2019	03/01/2019

All orders are subject to the terms and conditions in your current contract with Grainger or to Grainger's current Terms of Sale as set forth on Grainger.com

Thank You!

Visit us at grainger.com

Information

Date 01/22/2019
Customer Account Number 885295220
Grainger Quote Number 42494528

Item	Description Manufacturer Name & Model	Cat. Pg. #	Qty	\$ Quote	Ext. Price	Start Date	Exp. Date
1LLX7	Black Pipe Nipple,Threaded,1/4x4-1/2 In GRAINGER APPROVED 1LLX7 Country of Origin: Multiple	2769	1	5.04	5.04	01/22/2019	03/01/2019
6LFA3	Water Pressure Reducing Valve,3/4 In. BELL & GOSSETT B7-12 Country of Origin: India	2651	1	46.40	46.40	01/22/2019	03/01/2019
						Total \$ 228.11	

Thank You!
Visit us at grainger.com

REDUCING VALVE
PART NO. 110196 MODEL NO. B7-12
2B90 MAX. PRESS. MAX. TEMP. SET AT
125 PSI 225 F 12 lbs
ITT V57130

Access 8842 RWP - A

WARNING

NON-SUBMERSIBLE PUMP
THIS PUMP HAS NOT BEEN INVESTIGATED
FOR USE IN SWIMMING POOL OR MARINE AREAS
FOR USE IN SWIMMING POOL SEE
RISK OF ELECTRIC SHOCK. SEE
INSTRUCTION MANUAL FOR PROPER
THERMALLY PROTECTED
FOR SUPPLY CONNECTIONS USE COPPER
CONDUCTORS AT LEAST 90°C (194°F).
ACCEPTABLE FOR AT LEAST 90°C (194°F).

40 60
20 80
100

psi