

CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: DE002

Date of Visit: 2/13/19

Contractor Personnel on Site:

1. Chris Claycomb
2. _____
3. _____
4. _____
5. _____
6. _____

Service Call Number

CSS# 17414 WO# 7513

Description of Repairs

Adjusted LP Gas pressure on rooftop MAKE-UP
heater. Investigated wiring issues.
Found High Voltage @ Low Voltage, recommend
Contractor wiring to be checked by Contractor

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Chris Claycomb Date: 2/13/19

Signed: Chris Claycomb

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SSG Spates, Eric Date: 13 Feb 19

Signed: Eric Spates

E-Mail: eric.s.spates.mil@mail.mil