

## CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: PA209 Date of Visit: 3/5/2019

**Contractor Personnel on Site:**

1. Jarod Hack
2. \_\_\_\_\_
3. \_\_\_\_\_
4. \_\_\_\_\_
5. \_\_\_\_\_
6. \_\_\_\_\_

### Service Call Number

CSS# 17481 WO# 7533

### Description of Repairs

Replaced PTAC unit blower motor with new blower motor in room 139

## CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: **Jarod Hack** Date: **3/5/2019**

Signed: **Jarod Hack**

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: **Scott Kawski** Date: **5 March 19**

Signed: KAWSKI.SCOTT.WILLIAM.1017531154 Digitally signed by KAWSKI.SCOTT.WILLIAM.1017531154  
Date: 2019.03.05 14:25:13 -05'00'

E-Mail: [\[REDACTED\]](mailto:)







ROOM

70

**Amana®**

▼

^

COOL-OFF-HEAT

\* AUTO - ON

BATTERY POWERED - INSTRUCTIONS INSIDE COVER

ROOM 69

Am



COOL-OFF-HEAT

BATTERY POWERED - INSTRUCTIONS INSIDE COVER

ZHONGSHAN BROAD-OCEAN MOTOR CO., LTD. 0131P00002  
VOK-100042326-01  
VOLTS 208-230 HZ 60 AMPS 0.66  
RPM 1100/1500 CAP 5.5W/3.75WAC 6P  
INS CL. B PH1 100W LRA: 1.42A  
THERMALLY PROTECTED

UL

1746327



