

CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY032 Date of Visit: 3-27-19

Contractor Personnel on Site:

1. John Granata
2. _____
3. _____
4. _____
5. _____
6. _____

Service Call Number

CSS# 17565 WO# 7564 New # 8101

Description of Repairs

checked boiler air vent removed &
cleaned, verified operation of vent-ot. Pushed
air through system & each fan coil unit.
1 unit is plugged all others heating fine.

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Todd Mitchell Date: 4-2-19

Signed: Todd Mitchell

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: John Granata Date: 3-27-19

Signed: J.F. Granata

E-Mail: John.F.Granata.CTR@mail.mil





103.3

MAX 103.3

°C/°F

