

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: VA048-01 Date of Visit: 07-22-22

Contractor Personnel on Site:

1. <u>Will Schultz</u>	4. _____
2. _____	5. _____
3. _____	6. _____

Service Call Number

CSS# 1767 WO# 18684

Description of Repairs

Found coil froze up. Checked refrigeration levels, they were fine. Checked air flow from fan motor and found low. Replaced belt and took care of issue. Also was setting t-stat to low which unit could never reach target. Also cause of frozen coil.

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Will Schultz Date: 07-22-22

Signed: Will R. Schultz

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: andrew campbell Date: 07-22-22

Signed: andrew campbell

E-Mail: andrew.r.campbell.mil@army.mil

