

CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: M10003 Date of Visit: 03-05-2019

Contractor Personnel on Site:

1. Jimmy
2. _____
3. _____
4. _____
5. _____
6. _____


Service Calls – Service Call Number and Description

1. WO-7990 CSS 17968 BOILER FID. CONDUCTED TEST SUPPORT
2. TO FURTHER TROUBLESHOOT RAN SEVERAL DIAGNOSTIC TESTS
3. WITH TECHNICIAN FOUND ISSUE WITH GAS PRESSURE SAFETY INTERVAL
WIRING CORRECTED WIRING AND BOILER RUNNING NORMAL.

CERTIFICATION OF WORK

To be signed by the Contractor:


Print Name: James Spackman Date: 03-05-2019

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Jorge Mender/SGT Date: 03-05-2019

Signed: 

E-Mail: _____



2

Buderus
Logano plus GB312