

Additional Funding Request

MD002	CSS# 18496 WO# 8426 Asset# NA							
Description of Repairs	Labor and materials to unclog the sewage line in building 314.							
Diagnosis: Initial Work Order	While John was onsite at MD002 Bldg. 314 he found that the sewage lift is backing up most likely due to a clog in the line. Please request a ticket and we will get a plumber out. No one can use the bathrooms in this building until it is fixed.							
Diagnostic Fee	\$ 450.00 TW Labor \$80/hr x 2 Freedom Septic Services \$290 (See attached Invoice)							
Additional Labor Cost to Perform Repairs	\$ 900.00 S&S Mechanical Labor \$100/hr x 9							
Additional Material Cost to Perform Repairs	\$75.00 <table border="1"><tr><td>Snake</td><td>1</td><td>\$75.00</td><td>\$75.00</td></tr></table>				Snake	1	\$75.00	\$75.00
Snake	1	\$75.00	\$75.00					
Total Cost of Repair	\$ 1,425.00							



S&S Mechanical

Location: Curtis Bay US Army Reserve Center
700 E. Ordnance Rd
Baltimore, MD 21226

Proposal Submitted to: Adam Colopy
Project: MD002 Snake

Office # 301-574-1555

Fax # 301-574-1558

seth@sandsmidatlantic.com
sandsmidatlantic.com

S&S Mechanical is providing this quote to Tidewater for the backed-up sewer line for the building.

- S&S will provide the large snake machine and a technician to clear stopped up main line to septic system.
- S&S will ensure main line is clear of all obstructions and flush with clean water.
- S&S will open building back up for full operation once main is clear and all work complete.

Labor: \$975.00

1 Plumber/9Hours/\$100 rate

Snake charge: \$75.00

Full estimated total: \$975.00

Payments to be made as follows: 15 days upon approved invoice

Respectfully submitted: Brian Davis/Lindsay Ruby

Dated: 04/01/19

2809 Liberty Road
Sykesville, MD 21784
Phone: 410-795-2947

DATE	INVOICE #
4/2/2019	109685

BILL TO
Tidewater, Inc. Karlee Demain 6625-A Felinck Dr. Elkridge, MD 21075

P.O. NO.	TERMS	PROJECT

[illegible]

Web Site
www.poophappens.com

