

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: MD019 B-1 Date of Visit: 6/14/19

Contractor Personnel on Site:

- | | |
|----------------------|----------|
| 1. <u>John Brown</u> | 4. _____ |
| 2. _____ | 5. _____ |
| 3. _____ | 6. _____ |

Service Call Number

CSS# 19544 WO# 9035

Description of Repairs

I found no issues with either of the locking
cylinders they both worked perfectly. but I
did find a loose closer arm that wasn't allowing
the door to to secure without pulling it closed.
I secured the the nut on the arm so that it automatically latches

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Johnny W. Brown Date: 6/14/19

Signed: Johnny W. Brown

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SPC. Tyler Packard Date: 6/14/19

Signed: Tyler Packard

E-Mail: _____

