

CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY067 BLDG1 Date of Visit: 7/12/19

Contractor Personnel on Site:

Patrick Brown

1. _____	4. _____
2. _____	5. _____
3. _____	6. _____

Service Call Number

CSS# 20224 WO# 4734


Description of Repairs

I reset the fan motors an air handler control units then I
monitored the system for an hour to make sure it was operating
correctly, and I checked temperature's throughout the building

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Brown Date: 7/12/19

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Ammie Mearero Date: 7/12/19

Signed: 

E-Mail: _____

12-31-19 5:15 AM EDT

0 Unacknowledged Alarms

ALARMS

HV-1
HV-2
HV-3
HV-4
HV-5
VFD's
Chiller

HV1 1st Floor Damper Closed

HV1 Ground Floor Damper Closed

Fan Coil Enable On

Outdoor Air 67.6 °F

Cooling Mode Sp 55.0 °F Chiller Start/Stop On

Cooling Mode DB 5.0 °F Alarm Normal

CW Pump 1 Status On

CW Pump 2 Status Off

Chilled Water Supply 46.5 °F Return 41.3 °F

HV1 Space Temp 69.0 °F Setpoint 75.0 °F DB 4.0 °F

HV1 DA Lockout On Setpoint 60.0 °F DB 4.0 °F

screenshot showing Chiller is running properly

