

CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: MD019 B-3 Date of Visit: 8/1/19

Contractor Personnel on Site:

1. <u>John Brown</u>	4. _____
2. _____	5. _____
3. _____	6. _____

Service Call Number

CSS# 20510 WO# 10139

Description of Repairs

After the contactors were reset, they were concerned when they saw a yellow that stayed on. I checked it out and found that the light comes on when the call for the pumps is satisfied. it goes out when the pump is called to run .

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Johnny W. Brown Date: 8/1/19

Signed: Johnny W. Brown

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SFC Ryan Willoughby Date: 8/1/19

Signed: 

E-Mail: _____

