

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: MD024 B-1 Date of Visit: 8/20/19

Contractor Personnel on Site:

1. <u>John Brown</u>	4. _____
2. _____	5. _____
3. _____	6. _____

Service Call Number

 CSS# 20762 WO# 10596

Description of Repairs

I found the unit low on refrigerant. I checked the system for leaks and tightened all connections and valve stems. charged the unit. then after I got it cooling properly, I discovered that the thermostat was out of calibration so I replaced the T-stat.

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Johnny W. Brown Date: 8/20/19

Signed: Johnny W. Brown

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: CW4 Gerald A. Mitchell Date: 8/20/19

Signed: 

E-Mail: 



