

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: MD002 B-2 Date of Visit: 1/7/20

Contractor Personnel on Site:

1. <u>John Brown</u>	4. _____
2. <u>Alan Brooks</u>	5. <u>Wagner Cummins</u>
3. _____	6. _____

Service Call Number

CSS# 20763 WO# 11244

Description of Repairs

replaced defective 3 way solenoid valve with a new one .
Removed old defective manual blow down and replaced it with a
new electronic blow down drain. After work was completed the
unit was ran and monitored for proper operation.

CERTIFICATION OF WORK

To be signed by the Contractor:

Alan Brooks

Print Name: Johnny W. Brown

Date: 1/7/20

Signed: Johnny W. Brown 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SSG Darnell Currington Date: 1/7/20

Signed: 

E-Mail: _____



