

Region: 5

Location: md019

CSS #: 20811

Maximo Work Order No.: 12600

Asset #: NA

Date Issued: 09/10/20

Original Description: Brian is recommending an additional 250 Gallons to be added due air in the system-this is an estimate .. this has been an issue since the chiller barrel work was done by JCI --

Repairs Needed:

Bond Chemical will add additional Glycol needed. SS Mechanical will be on site to coordinate efforts and check system.

RS Means Line Buildup and Labor Summary (Data Version 2017, Q4):

Quantity	Line Item Number	Description	Labor Hours	Labor Rate/Hr	Materials	Equipment	Total
--	NA	275 gallons De-ionized Water	--	--	\$907.50	--	\$907.50
--	NA	Equipment see detail in Bond Quote	--	--	\$840.00	--	\$840.00
		1 leadman	4	\$120.00	--	--	\$480.00
--	NA	1 leadman @120x4hrs 2 Techs @\$65 x 8 hrs	8	\$65.00	--	--	\$520.00
		SS Mechanical	10	\$100.00	--	--	\$1,000.00
--	NA	TW Coordination	3	\$80.00	--	--	\$240.00

Estimate Summary:

Labor Hours	Labor Cost	Material Cost	Equipment	Total Cost	CE Factor	Total Estimate
25	\$2,240.00	\$907.50	\$840.00	\$3,987.50	106%	\$4,226.75



WATER TECHNOLOGIES, INC.

QUOTE

Supported By Technology

De-Ionized Water Addition Quotation for MD-019

Date: August 24, 2020
QUOTE #1367
Expiration Date: 12/30/20

To Adam Colopy
Tidewater Inc
MD-019
12100 Greenspring Ave
Owings Mills, MD 21117

Salesperson	Job	Shipping Method	Shipping Terms	Delivery Date	Payment Terms	Due Date
Jon Miller, CWT	MD 019	BOND	BOND		Net 30	12/30/20

Qty	Item #	Description	Unit Price	Line Total	
4 hours		Installation of New De-ionized Water	\$250.00	3 technicians - 4 hours	\$1,000.00
5 x 55 Gallons		De-ionized Water	\$3.30/gallon	275 Gallons	\$907.50
		Delivery with Lift Gate Fee	\$100.00		\$100.00
		Pump with compressor rental delivery and pickup	\$640.00		\$640.00
		Empty Drum Pickup	\$100.00	Pickup	\$100.00
				Subtotal	\$2,747.50
				Sales Tax	\$54.45
				Total	\$2,801.95

Quotation prepared by: Jon Miller, CWT Account Manager

This is a quotation on the goods named, subject to the conditions noted below: (Describe any conditions pertaining to these prices and any additional terms of the agreement. You may want to include contingencies that will affect the quotation.)

To accept this quotation, sign here and return: _____

Questions? Please contact Jon Miller, CWT @ 301-580-9820

BOND Water Technologies, 630 E. Diamond Ave. Suite J/K Gaithersburg, MD 20877
Phone 301-721-BOND Fax 301-721-0858 jmiller@bondwater.com



S&S MECHANICAL

S&S Mechanical
4845 South Crain Highway
Upper Marlboro, MD 20772

Tel. 1 - (301) 574-1555
Fax. 1 - (301) 574-1558
www.sandsmidatlantic.com

CUSTOMER QUOTATION NO. 369

Tidewater, Inc.
Tidewater, Inc
6625 Selnick Dr.
Suite A
Elkridge MD 21075

Quote Name: 12600
Quote No: 369
Site: MD019 Greenspring Avenue
Site Contact:
Salesperson: Lindsay Ruby
Created Date: 09/10/2020
Valid For: 30 Day(s)

WO#: 12600

CSS Ticket #: 20811

Problem: Can I please get a quote for Brian to be on site at MD019 for the Oversight of the additional GLYCOL that has to be added.

S&S will oversee the addition of 250 gallons of glycol being added to the system by JCI.

Service

Item	Quantity	Unit Price	Total
HVAC Labor Rate	10	\$100.00	\$1,000.00
		Sub-Total ex Tax	\$1,000.00
		Tax	\$0.00
		Total inc Tax	\$1,000.00

Labor	\$1,000.00
Sub-Total ex Tax	\$1,000.00
Tax	\$0.00
Total inc Tax	\$1,000.00