

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: MD019 B-1 Date of Visit: 9/20/19

Contractor Personnel on Site:

1. John Brown
2. _____
3. _____
4. _____
5. _____
6. _____

Service Call Number

CSS# 21390 WO# 11036

Description of Repairs

I replaced flush-o-meter diaphragm, I adjusted the water flow and fill the floor drain trap. it was completely dry.

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Johnny W. Brown Date: 9/20/19

Signed: Johnny W. Brown

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: 1st SGT Nate Maze Date: 9/20/19

Signed: Nate

E-Mail: _____

