

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY013 BLDG1 Date of Visit: 11/26/19

Contractor Personnel on Site:

- | | |
|------------------------|-------------------------|
| 1. <u>HYDE-STONE</u> | 4. <u>TIDEWATER</u> |
| 2. <u>Matt Russell</u> | 5. <u>Patrick Brown</u> |
| 3. _____ | 6. _____ |

Service Call Number

CSS# 21635 WO# 5692

Description of Repairs

Replaced two auto air vents , One Reducing valve and cleaned/
serviced both boilers

CERTIFICATION OF WORK

To be signed by the Contractor:


Print Name: Matt Russell Date: 11/26/19

Signed: _____

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SFC KEVIN Stewart Date: 11/26/19

Signed: 

E-Mail: _____

