

## Additional Funding Request

<b>NY013</b>	<b>CSS# 21635 WO# 5692 Asset# 9218 and 9219</b>
Description of Repairs	Labor and Materials to service two boilers (Lochinvar, Model # KBN501, Serial #D12H10214648 and D12H10211228) and to install two auto air vents and 1 pressure reducing valve (3/4).
Diagnosis: Initial Work Order	NO1 BOILER ON LOCK OUT, NO2 Boiler MAKING ALL SORTS OF NOISE WHEN IT FIRES UP. Urgent
Diagnostic Fee	\$430  Hydestone - \$430
Additional Labor Cost to Perform Repairs	\$1,000  Hydestone labor 8 hours @ \$95/hr TW Labor 3 hours @ \$ 80/hr
Additional Material Cost to Perform Repairs	\$433.78  Various materials (See attached Detail)
Total Cost of Repair	<b>\$1,863.78</b>

**PROJECT ESTIMATE**

DATE: 10/28/2019

QUOTE ID: 4555  
AR CUSTOMER: TIDE WATER, INC (#922)  
SERVICE LOCATION: U.S. ARMY RESERVE - TIDE WATER  
STREET: 45 WEST MAIN ST.  
CITY: CANTON, NY 13617

CONTACT: Patrick Brown  
Ph:(315) 672-3272  
patrickbrown2007@gmail.com  
DATE SUBMITTED: 10/28/2019  
PREPARED BY: FRASHER, LINDA

DESCRIPTION: Boiler Service

SCOPE OF WORK: We were called to look into issues with two boilers. Checked in with Patrick. Found boiler 1 tripped on high outlet temp. Could not get it to reset. After several attempts it reset. This is not normal to have happening. Once it reset, I kept tripping out on high outlet temp. Found auto reset set point at 150. Target temp is 160. Turned it to where it should be. 180. Boiler is now cycling as it should. Patrick would like a quote in servicing these.

The pricing shown below covers labor, materials and applicable taxes to service two boilers (Lochinvar, Model # KBN501, Serial # D12H10214648 and D12H10211228) and to install two auto air vents and 1 pressure reducing valve (3/4) as well as TIME SPENT on October 23. Please call me at extension #236 if you have any questions. Thank you.

EQUIPMENT: Make: LOCHINVAR, M#:KBN501, S#: D12H10214648, BOILER, Eq#: 15753

ITEM	QUANTITY	UNIT PRICE	TOTAL
Labor Regular Time	8	\$95.00	\$760.00
Auto Air Vents	2	\$40.00	\$80.00
Pressure Reducing Valve	1	\$142.00	\$142.00
Gaskets	2	\$39.75	\$79.50
Environmental Fee	1	\$12.00	\$12.00
TIME SPENT on October 23 (\$50.00 - Vehicle, \$380.00 - Labor)	1	\$430.00	\$430.00
<b>Tax</b>			\$120.28
<b>Total</b>			\$1,623.78

---

SIGNATURE

---

PRINT NAME

---

DATE

**PROJECT ESTIMATE**

DATE: 10/28/2019

All material is guaranteed to be as specified. All work to be completed in a workmanlike manner according to standard practices. Any alteration or deviation from the above specifications involving extra costs will be executed only upon written orders, and will become an extra charge over and above the estimate.

All agreements contingent upon strikes, accidents or delays beyond our control. Our technicians are covered by New York State Workers Compensation Insurance.

QUOTE VALID FOR THIRTY (30) DAYS

