

Region: 2

Location: NY051

CSS #: 22659

Maximo Work Order No.: 6483

Asset #: 10044

Date Issued: 9/26/19

Original Description:

BERINGS BAD IN MOTOR

Repairs Needed:

Labor and materials to replace hot water circulating pump.

Note: 5-6 week lead time on pump.

RS Means Line Buildup and Labor Summary (Data Version 2017, Q4):

Quantity	Line Item Number	Description	Labor Hours	Labor Rate/Hr	Materials	Equipment	Total
--	NA	Materials (See attached detail)	--	--	\$5,398.74	--	\$5,398.74
--	NA	Tidewater Labor (Diagnostic and Repair)	14	\$80.00	--	--	\$1,120.00

Estimate Summary:

Labor Hours	Labor Cost	Material Cost	Equipment	Total Cost	CE Factor	Total Estimate
14	\$1,120.00	\$5,398.74	\$0.00	\$6,518.74	90%	\$5,866.87



WORK ESTIMATE

CSS #:

22659

Work Order #:

6073

Emergency

Urgent

Routine

Company Name:	Tidewater, Inc.	Facility ID:	NY051
Contractor POC:	Adam Colopy		
Telephone No:	740-819-6207	Building/Location; (e.g., Classroom/Room #)	Mech Room
E-Mail Address:	adam.colopy@tideh2o.net		
Assigned Technician(s):	Patrick Brown		

DESCRIPTION of WORK and EXPLANATION for REPAIRS or REPLACEMENT

Labor and materials to replace circulating pump.

Note: 5-6 week lead time on pump.


LABOR/MATERIAL		MATERIAL/ SUB UNIT DOLLAR AMOUNT	LBR/HR \$80	LINE ITEM TOTAL DOLLAR AMOUNT
ITEM	QUANTITY			
Labor			10	\$800.00
Bell & Gossett E-1510 Circulating Pump	1	\$4,857.48		\$4,857.48
Shipping	1	\$185.00		\$185.00
Sales Tax				\$356.26
Diagnostic Labor			4	\$320.00
SUB-TOTAL COSTS:		Materials Total	\$5,398.74	Labor \$1,120.00
		TOTAL		\$6,518.74



Search the store



HOME / CIRCULATING PUMPS / BELL & GOSSETT E-1510 1.5BC PUMP 3 HP 1750 RPM 3 PHASE TEFC



BELL & GOSSETT

Bell & Gossett e-1510 1.5BC Pump 3 HP 1750 RPM 3 Phase TEFC

(No reviews yet)

[Write a Review](#)**MPN:** 1.5BC**CONDITION:** New**AVAILABILITY:** This Item Usually Ships In 3-5 Days!**SHIPPING:** \$185.00 (Fixed Shipping Cost)**\$4,047.90****QUANTITY:**

