

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: VA 050 Date of Visit: 1.24.20

Contractor Personnel on Site:

- | | |
|--------------------------|----------|
| 1. <u>Richard Walker</u> | 4. _____ |
| 2. _____ | 5. _____ |
| 3. _____ | 6. _____ |

Service Call Number

CSS# 22780 WO# 11292

Description of Repairs

Removed old inducer motor/Bulder housing.
Installed New motor to housing, and
installed onto boiler. Turned gas/water back on.
Tested for normal ops.

CERTIFICATION OF WORK

To be signed by the Contractor:


Print Name: Richard Walker Date: 1.24.20

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Villareal, Francisco ^{CW} Date: 1.24.20

Signed: 

E-Mail: _____

