

**CERTIFICATION OF WORK  
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: VA049 Date of Visit: 1/15/2020

Contractor Personnel on Site:

1. Richard Walker
2. \_\_\_\_\_
3. \_\_\_\_\_
4. \_\_\_\_\_
5. \_\_\_\_\_
6. \_\_\_\_\_

**Service Call Number**

CSS# 23375 WO# 11577

**Description of Repairs**

Found 3 doors @ Bldg #5 Not locking /closing.


1. Civilian door - Backing plate was loose. (Tightened, Tested, working).
2. Office Door - Is cross locking pin, with half step locking. Adjusted, and had personnel test. (3). Storage door.

Arm was preventing door from unlocking. (Adjusted Arm had personnel Test and approve.

**CERTIFICATION OF WORK**

To be signed by the Contractor:

Print Name: Richard Walker Date: 1/15/2020

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: GS11 Mark Anderson Date: 1/15/2020

Signed: 

E-Mail: mark.s.anderson7.mil@mail.mil

Bldg # 3



Door # 1



Cross Pin  
Adjustment



Backing



Loose

Door # 2



Bldg # 3

