

## Additional Funding Request

<b>MD002</b>	<b>CSS# 23413 WO# 11584 Asset# NA</b>			
Description of Repairs	Labor and materials to replace bad circulating pump on boiler #1			
Diagnosis: Initial Work Order	Replace Circ pump, boiler 1, bldg. 001.			
Diagnostic Fee	\$160			
Additional Labor Cost to Perform Repairs	\$320 TW Labor 4 hours @ \$ 80			
Additional Material Cost to Perform Repairs	\$417.15			
	Circulating Pump (MPN: 103351LF) (see detail attached)	1	\$417.15	\$417.15
Total Cost of Repair	\$897.15			



# WORK ESTIMATE

CSS #: 23413

Work Order #: 11584

Emergency ☐

Urgent ☐

Routine ☒

Company Name:	Tidewater, Inc.	Facility ID:	MD002
Contractor POC:	Adam Colopy		
Telephone No:	740-819-6207	Building/Location; (e.g., Classroom/Room #)	Boiler #1
E-Mail Address:	<a href="mailto:adam.colopy@tideh2o.net">adam.colopy@tideh2o.net</a>		
Assigned Technician(s):	John Brown		

## DESCRIPTION of WORK and EXPLANATION for REPAIRS or REPLACEMENT

Labor and materials to replace bad circulating pump on boiler #1.

LABOR/MATERIAL		MATERIAL/ SUB UNIT DOLLAR AMOUNT	LBR/HR \$80	LINE ITEM TOTAL DOLLAR AMOUNT
ITEM	QUANTITY			
Labor			4	\$320.00
Circulating Pump (MPN: 103351LF) (see attached detail)	1	\$393.54		\$393.54
Sales Tax	1	\$23.61		\$23.61
Diagnostic Labor			2	\$160.00
SUB-TOTAL COSTS:	Materials Total	\$417.15	Labor	\$480.00
TOTAL			\$897.15	



BELL & GOSSETT

## 103351LF Bell & Gossett NBF-33 Circulating Pump 1/15 HP

★★★★★ (1 review) [Write a Review](#)

**MPN:** 103351LF

**CONDITION:** New

**AVAILABILITY:**

This Item Usually Ships The Same Day!

**SHIPPING:** Calculated at Checkout

**\$327.95**



DESIGNED IN U.S.A.



**BELL &  
GOSSETT  
CIRCULATOR**

**NBF-33 103351LF 1C21**

**115V 60HZ 1Ø CLASS F 1.1A 125W**

**MAXIMUM RATING**

**LIQUID TEMP.**

**240°F/115°C**

**PRESSURE**

**150PSI/10BAR**

**IMPEDANCE PROTECTED**

**LEO-F**

ENC.2



**LISTED**

**3680**



**WATER CIRCULATING PUMP**

**Made in China**

**ITT**

P83032

103351



