

## Additional Funding Request

<b>MD019</b>	<b>CSS# 23465 WO# 11717 Asset# NA</b>			
Description of Repairs	Labor to continue to trouble shoot why system is over pressurizing and coming out the relief valve. Already replaced the valve and system continues to leak. AFOS also working to locate plumbing drawings to assist with investigation.			
Diagnosis: Initial Work Order	There was a pressure relief valve that was leaking in the pump house and caused a short in the pull station located directly beneath it. Need to have pressure relief valve repaired and tested to make sure that it doesn't leak anymore. Need to have this done because the pumps have been shut off in order to stop the valve from leaking and possibly burning out the well pump or drying up the well. Once the valve issue is taken care of, need to make sure the pumps are turned back on.			
Diagnostic Fee	\$ 450			
Additional Labor Cost to Perform Repairs	\$ 1000  Labor \$100/hr x 10			
Additional Cost	\$ <div style="border: 1px solid black; width: 500px; height: 20px; margin-top: 5px;"></div>			
Total Cost of Repair	\$ 1,450.00			



**S&S MECHANICAL**

**S&S Mechanical**  
4845 South Crain Highway  
Upper Marlboro, MD 20772

Tel. 1 - (301) 574-1555  
Fax. 1 - (301) 574-1558  
www.sandsmidatlantic.com

## CUSTOMER QUOTATION NO. 174

Tidewater, Inc.  
Tidewater, Inc  
6625 Selnick Dr.  
Suite A  
Elkridge MD 21075

**Quote Name:** 11717  
**Quote No:** 174  
**Site:** MD019 Greenspring Avenue  
**Site Contact:**  
**Salesperson:** Lindsay Ruby  
**Created Date:** 01/30/2020  
**Valid For:** 30 Day(s)

**WO#: 11717**

**CSS Ticket Number: 23465**

Problem: There was a pressure relief valve that was leaking in the pump house and caused a short in the pull station located directly beneath it. Need to have pressure relief valve repaired and tested to make sure that it doesn't leak anymore. Need to have this done because the pumps have been shut off in order to stop the valve from leaking and possibly burning out the well pump or drying up the well. Once the valve issue is taken care of, need to make sure the pumps are turned back on."

S & S will need additional labor to further diagnose.

### Service

Item	Quantity	Unit Price	Total
Diagnosis Fee	1	\$450.00	\$450.00
HVAC Labor Rate	10	\$100.00	\$1,000.00
<b>Sub-Total ex Tax</b>			\$1,450.00
<b>Tax</b>			\$0.00
<b>Total inc Tax</b>			\$1,450.00
<b>Labor</b>			\$1,450.00
<b>Sub-Total ex Tax</b>			\$1,450.00
<b>Tax</b>			\$0.00
<b>Total inc Tax</b>			\$1,450.00



[illegible]