

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: VA006 Date of Visit: 5/15/2020

Contractor Personnel on Site:

- | | |
|--------------------------|----------|
| 1. <u>Richard Walker</u> | 4. _____ |
| 2. _____ | 5. _____ |
| 3. _____ | 6. _____ |

Service Call Number

CSS# 23672 WO# 11748

Description of Repairs

Cleaned and installed new gaskets on booster pump. Checked system
verified no leaks. Work complete

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Richard Walker Date: 5/15/2020

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Donald Hinson Date: 5/15/2020

Signed: 

E-Mail: _____







