

CERTIFICATION OF WORK

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: Brandt Bld 314

Date of Visit: 1-29-20

Contractor Personnel on Site:

1. Keith Pearson
2. WADE STAHL
3. _____

4. _____
5. _____
6. _____

Service Calls – Service Call Number and Description

1. main Ent. Not Releasing
2. _____
3. _____

Diagnosed defective strike, replaced w/new

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Keith Pearson

Date: 1-29-20

Signed: _____

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Brian Wharton GS11

Date: Jan 29 2020

Signed: _____

E-Mail: _____

Brian. w. wharton.civ@mail.mil

314

U.S. ARMY
RESERVE CENTER







Product Components

ASSA ABLOY

on Instru

9400

© 9400/9500/9600/9700 Strike Rod

mes
ASSA ABLOY

CLASSIFIED
LATCHING HARDWARE
IN ACCORDANCE WITH
SDI-BHMA A250.13

