

WO 268410

**CERTIFICATION OF WORK  
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: MD002

Date of Visit: 9-15-20

Contractor Personnel on Site:

1. Chris 4. \_\_\_\_\_
2. Donald Hirschowitz 5. \_\_\_\_\_
3. Philip Poehitz 6. \_\_\_\_\_

**Service Call Number**

CSS# 23957 WO# 11783


**Description of Repairs**

Remove And Replace Bottom weather seal and make  
Poor repair for Constant Contact

**CERTIFICATION OF WORK**

To be signed by the Contractor:

Print Name: Donald Hirschowitz Jr Date: 9-15-20

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Nicol, Christo SSG Date: 9-15-20

Signed: 

E-Mail: Christo.nicol.mil@mail.mil







**Overhead Door Company of  
Baltimore**

3501 Century Ave  
Baltimore, MD 21227  
Phone: 410-636-6300  
Fax: 410-789-1053

**Work Order  
Receipt**

Order Number : 268410  
Printed: 9/16/2020 3:28:25 PM by KaylieW

<b>Bill to:</b> TIDEWATER, INC. 6625 SELNICK DR. SUITE A Elkridge, MD 21075	<b>Ship to:</b> Army Reserve MD002 700 E Ordance Rd Baltimore, MD 21226
<b>Email Address:</b> tidewaterap@tideh20.net	<b>Map:</b>
<b>Authorized:</b> Tina Lee	<b>Job Contact:</b> Tina Lee
<b>Phone:</b> (410) 997-4458	<b>Job Phone:</b> 614-623-9569
<b>2nd Phone:</b>	<b>2nd Phone:</b>
<b>Fax:</b> (410) 997-8713	<b>Fax:</b>

Created By	PO Number	Customer	Salesperson	Terms
John Gunnet	WO 11783	20130	50	30

**Work Order Note:** FURNISH AND INSTALL: 51.0000 (FEET) W/S - Rodent Proof Bottom Weatherstrip Qty (3) 16'2" ALUMINIUM BOTTOM SEAL RETAINER T SHAPED FOR ANGLE BAR Scope of Work: We will remove and replace the bottom rubber seal on three of the rolling steel doors where we installed new operators. The new T type retainer will hold the rodent guard bottom rubber seal to the bottom of the three doors. All three operators will be wired for constant pressure close. The customer will provide us with an escort to the building.

**ITEMS USED:**

Item Qty	Item #	Description	Unit of Measure
1.0000	500	*Service Provided On	EACH
53.0000	13378	W/S - Rodent Proof Bottom Weatherstrip	FEET
53.0000	13356	ALUMINIUM BOTTOM SEAL RETAINER T SHAPED FOR ANGLE BAR	FEET
1.0000	COMFUEL	COMMERCIAL FUEL SURCHARGE	EACH

**HOURS USED:**

Qty	Unit of Measure	Labor ID	Description
4.0000	HOUR	LABCS	LABOR COMMERCIAL SERVICE

**WORK PERFORMED CODES:**

Serviced Door	Serviced Operator	Replaced Bottom Weather Seal	Limited Parts Warranty On Repair ONLY
---------------	-------------------	------------------------------	---------------------------------------

**Description of work performed:**

**Mechanic Name:** Don Hirshcowitz/ Matt

Dunton -160

**Date of Work:** 9/15/2020

**Comment:**

Added t type retainer and rodent seal and made all 3 doors constant contact all units are working good

**Signature:**



**Date:** 9/15/2020

**Printed name and title:** Chris to Nicol

**Terms And Conditions Of Agreement:**

ACCEPTANCE - Customer(s) signature at the base of this agreement is an acknowledgment that the customer(s) has inspected the work performed above and said work is acceptable and satisfactory.