

CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: VA 048 Date of Visit: 3.4.20

Contractor Personnel on Site:

1. Richard Walker
2. _____
3. _____
4. _____
5. _____
6. _____

Service Call Number

CSS# 23982 WO# 11786

Description of Repairs

Removed faulty Board/harness in Room # 105.
Installed Board and harness from Room# 214B.
Tested Unit for proper operations.
PPAC Control working.

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Richard Walker Date: 3.4.20

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: RFOS Date: 3.4.20

Signed: 

E-Mail: _____

