

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: VA048 Date of Visit: 6/3/20

Contractor Personnel on Site:

1. William Wynn 4. _____
2. Chris Crosswhite 5. _____
3. _____ 6. _____

Service Call Number

CSS# 23989 WO# 11797

Description of Repairs

Door 1 - Found set screws loose and spokets out of alignment, aligned spokets, and applied loctite to set screws. General serviced door.

Door 3 - applied loctite to set screws general serviced door
Door 3 - applied loctite to set screws reset limits general serviced door.

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: William Wynn Date: 6/3/20

Signed: William Wynn

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Braden Reed GS-07 Date: 20200603

Signed: Braden Reed

E-Mail: Christina.M.Winfield.civ@mail.mil



OVERHEAD DOOR

The Genuine. The Original.



Overhead Door Company
of Central Virginia

Richmond
(804) 550-1300

Fredericksburg
(540) 684-5757
Door 3
Serviced with Pride by:

Date

196
6/31/10