

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: VA 01 Date of Visit: 3.19.20

Contractor Personnel on Site:

1. <u>Richard Walker</u>	4. _____
2. _____	5. _____
3. _____	6. _____

Service Call Number

CSS# 24286 WO# 11959

Description of Repairs

Tried clearing mech Room drains. Went to nearest clean out. Ran 35ft before hitting 8ft of mud. Cleared/cut mud. Connected hose to domestic Supply and ran hose to mech room drain. Ran water through drain. Checked flow in outdoor clean out. Drain works now.

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Richard Walker Date: 3.19.20

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Chris Chipp Date: 3.19.20

Signed: 

E-Mail: _____

