



Proudly serving the entire states of Virginia & North Carolina.

Altavista, VA • Charlottesville, VA • Chesapeake, VA • Manassas, VA
Lynchburg, VA • Richmond, VA • Raleigh, NC • Charlotte, NC

P.O. Box 119 • Altavista, VA • 800.789.7199 • service@mooreselectric.com

Billing Address	Site Address
Customer: TIDEWATER, INC Address: 6625 SELNICK DRIVE ELKRIDGE MD 21075 Phone: 614-623-9569	Customer: USARC VA050 N CHESTERFIELD Address: 6002 STRATHMORE ROAD NORTH CHESTERFIELD VA 23232 Phone: 6146239569
Service Call #: COM0128207	Call Type: COM-HVAC


Service Requested
CSS 24292 WO 11960 VA050 - Chiller compressor is shorting out in 20 ton asset #2347

Problems					
Description	Tech	Equip. Desc and Model	Manufacturer	Equip. Serial	Asset ID
TROUBLE SHOOT UNIT	JEREMYGRAY	20 ton chiller M#CGAFC204ARA1000DE	Trane	C09E14915	

Tech Notes
Site Start - 3/17/2020 9:00 AM Site Stop - 3/17/2020 2:00 PM Arrived on site. Checked in with facilities manager on duty. Chiller had to alarms Low temperature cut out and Low outdoor ambient temperature. "LTO" Southpoint is set at 35°. I Adjusted the "LOAT" from 55° to 60°. The supply water temperature 55° return water temperature is 60°. System is operating properly at this time. Clean site. Job complete.

Labor			
Date	Technician	Description	Hours
3/17/2020	JEREMIAH GRAY	COMMERCIAL TRAVEL TIME	1.00
3/17/2020	JEREMIAH GRAY	REGULAR HVACR LABOR	5.00

Materials			
Date	Part Number	Description	Quantity
No records found			

Signed By Scott	Signature 	Date 3/17/2020
------------------------	---	-----------------------