

Additional Funding Request

VA048	CSS# 24362 WO# 11968 Asset# NA									
Description of Repairs	After multiple attempts to repair this unit by swaping boards and components we now recommend replacement. Labpr and materials to replace unit with new in Room 105									
Diagnosis: Initial Work Order	PTAC control board in Room 105, is not working again. Was replaced again with used board and was working fine for about 24 hrs. Only the power comes on now.									
Diagnostic Fee	\$0									
Additional Labor Cost to Perform Repairs	\$480 TW Labor 6 hours @ \$ 80									
Additional Material Cost to Perform Repairs	\$1,318.95 <table border="1" style="width: 100%;"><tr><td style="width: 40%;">Wall Air Conditioner (Model AZ65H09DAB) (see detail attached)</td><td style="width: 10%; text-align: center;">1</td><td style="width: 10%; text-align: center;">\$1,318.95</td><td style="width: 10%;"></td><td style="width: 10%; text-align: center;">\$1,318.95</td></tr></table>					Wall Air Conditioner (Model AZ65H09DAB) (see detail attached)	1	\$1,318.95		\$1,318.95
Wall Air Conditioner (Model AZ65H09DAB) (see detail attached)	1	\$1,318.95		\$1,318.95						
Total Cost of Repair	\$1,798.95									



WORK ESTIMATE

CSS #:

Work Order #: 11968

Emergency

Urgent

Routine

X

Company Name:	Tidewater, Inc.		Facility ID:	VA048
Contractor POC:	Adam Colopy			
Telephone No:	740-819-6207		Building/Location; (e.g., Classroom/Room #)	Room 105 PTAC Unit
E-Mail Address:	adam.colopy@tideh2o.net			
Assigned Technician(s):	Richard Walker			

DESCRIPTION of WORK and EXPLANATION for REPAIRS or REPLACEMENT

After multiple attempts to repair this unit by swapping boards and components we now recommend replacement. Labor and materials to replace unit with new in Room 105

LABOR/MATERIAL		MATERIAL/ SUB UNIT DOLLAR AMOUNT	LBR/HR \$80	LINE ITEM TOTAL DOLLAR AMOUNT
ITEM	QUANTITY			
Labor			6	\$480.00
Wall Air Conditioner (Model AZ65H09DAB) (see attached detail)	1	\$1,273.32		\$1,273.32
Sales Tax	1	\$45.63		\$45.63
Diagnostic Labor				
SUB-TOTAL COSTS:		Materials Total	\$1,318.95	Labor \$480.00
		TOTAL	\$1,798.95	



GE Zoneline 9,700 BTU 12.2 EER 230V Wall Air Conditioner - AZ65H09DAB

[Be the first to write a review](#)



Abt Model: AZ65H09DAB | UPC: 084691815754

✓ Available For Delivery 7 To 14 Days

\$1,061.10 \$1,179.00

[Special financing offers or lease 49.00/week](#)

Cooling BTU: 9700

12100 \$1,079.10	14400 \$1,106.00	7100 \$1,043.10	9700 \$1,061.10
---------------------	---------------------	--------------------	--------------------

Installation options available

CALL TO ORDER

[Add to Registry](#)

[Add to List](#)



Cool

Mode

64

Fan

+

-

High

Low

Display
Show/Hide