

CERTIFICATION OF WORK

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: DE 007

Date of Visit: 10/7/2020

Contractor Personnel on Site:

1. Bryan Davis

4. _____

2. _____

5. _____

3. _____

6. _____

Service Calls – Service Call Number and Description

1. Boiler not running adjustment screen stoppers
2. Installer boiler needs gas regulator
3. _____

WO# 12447 CSS# 25176

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Bryan Davis Date: 10/7/2020

Signed: Bryan Davis

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Dawell Bennett Date: 10/7/20

Signed: Dawell Bennett

E-Mail: _____

BALDOR • RELIANCE®

Super-E Motor

CAT. NO.	EM3611T							
SPEC.	36Q570S266G1							
HP	3							
VOLTS	230/460							
AMPS	8.4/4.2							
R.P.M.	1760							
FRAME	182T	HZ	60	PH	3			
SER. F.	1.15	CODE K	DES. B	CLASS	F			
NEMA NOM. EFF.	89.5	%	P.F.	75				
RATING	40C AMB-CONT							
CC	010A	USABLE AT 208V			9			
BEARINGS	DE 6206	ODE 6205						
ENCL	TEFC	SN	F1602251150					
VPWM INVERTER READY								
CT 6-60 Hz (10:1) VT 3-60 Hz (20:1)								
USABLE AT	50Hz	3HP	190/380V	9.6/4.8A	SF1.0			
BALDOR ELECTRIC CO. FT. SMITH, AR. MFG. IN U.S.A.								
NP3441LUA								

NEMA
Premium

Energy Verified
MC 183051

RU