

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY051 BLDG1 Date of Visit: 7/24/20

Contractor Personnel on Site:

1. <u>Patrick Brown</u>	4. <u>Hyde-Stone</u>
2. _____	5. _____
3. _____	6. _____

Service Call Number

CSS# 25493 WO# 9325


Description of Repairs

two temperature censors and two co2 sensors
were removed and replaced with new censors

CERTIFICATION OF WORK

To be signed by the Contractor:


Print Name: Patrick Brown Date: 7/24/20

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SFC ERIC ABBOTT Date: 7/24/20

Signed: 

E-Mail: _____

