

**CERTIFICATION OF WORK  
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: VA048 Date of Visit: 12.01.2020

Contractor Personnel on Site:

1. _____	4. _____
2. _____	5. _____
3. _____	6. _____

**Service Call Number**

CSS# \_\_\_\_\_ WO# 12597

**Description of Repairs**

found coil clean, filter clean, and condensate line free of blockage.

found condensation leaking through partially damaged sealant.

removed metal tape, from ceiling unit AC and resealed air conditioner.

---

---

**CERTIFICATION OF WORK**

To be signed by the Contractor:

Print Name: Richard Walker Date: 12.01.2020

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: \_\_\_\_\_ Date: 12.01.2020

Signed: 

E-Mail: \_\_\_\_\_

