

CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: VA049 Date of Visit: 08/12/2020

Contractor Personnel on Site:

1. <u>Simon Beltz</u>	4. _____
2. _____	5. _____
3. _____	6. _____

Service Call Number

CSS# 26152 WO# 12609

Description of Repairs

Cut existing PVC drain out and installed an EZ Trap with overflow safety. Insulated drain line, trap, and condensate pump. Cleared water from emergency drain pan and sealed drain pan outlet seal with silicone. Rewired condensate pump safety and drain pan safety to shut system off in event of condensate overflow situation. System is operating normally at this time. Air handler may continue to sweat until insulation inside air handler is dried completely,

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Simon Beltz Date: 8/12/2020

Signed: Simon Beltz

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Mark Anderson Date: 8/12/2020

Signed: _____ Date: 9/1/2020

E-Mail: mark.s.anderson7.mil@mail.mil















