

## CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: VA048 Date of Visit: 10.26.2020

Contractor Personnel on Site:

1. \_\_\_\_\_
2. \_\_\_\_\_
3. \_\_\_\_\_
4. \_\_\_\_\_
5. \_\_\_\_\_
6. \_\_\_\_\_

### Service Call Number

CSS# 26185 WO# 12612

### Description of Repairs

Removed old Trane ptac unit, cleaned sleeve in wall, and installed new Ptac in room #208.

re installed wall outlet to fit new power cable.

adjusted ptac to tenants preferred temperature.

---

---

---

## CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Richard Walker Date: 10.26.2020

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: MA6 MW, MC LISTEN LIC Date: 10.26.2020

Signed: 

E-Mail: \_\_\_\_\_

