

CERTIFICATION OF WORK

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID: UFICA

Date of Visit: 8-26-20

Building: UFCA motor pool

CSS: 26343

Contractor Personnel on Site:

CMMS: WO-10250

1. Keith Pearson

Service Order: ☒

2. MATT LoRusso

Corrective Maintenance: ☐

Service Order Work Performed:

Unit: Gate operator - Access Control

Manufacturer: _____

Model: _____

Serial: _____

Description: Found the Following : Blown out CPU Strike
on m.p. main door Reader at Gate, Black Bbx copper to Ethernet
found Bumper module in Gate operator No Good communicators

Repairs: Replaced All Above mentioned, Reprogrammed
tested & Demonstrated

To be signed by the Contractor:

Print Name: Keith Pearson Date: 8-26-20

Signed: [Signature]

To be signed by Facility Manager:

I certify that the above named individuals representing the Contractor arrived on site and to the best of my knowledge, completed the stated work listed:

Print Name/Rank: Zaleski, Connery T. GS-09 Date: 8-26-20

Signed: [Signature]

E-Mail: Connery.T.Zaleski.Civ@mail.mil















