

Region: 2

Location: NY127

CSS #: 26351

Maximo Work Order No.: 10242

Asset #: 190917 636

Date Issued: 8/25/20

Original Description:

Repair hot water pump #2 control board. Control Board is not working.

Repairs Needed:

Labor and materials to replace hot water pump HWP 2 T. Note 4 week lead time for pump.

RS Means Line Buildup and Labor Summary (Data Version 2017, Q4):

Quantity	Line Item Number	Description	Labor Hours	Labor Rate/Hr	Materials	Equipment	Total
	NA	Materials (See attached detail)			\$2,952.77		\$2,952.77
	NA	Tidewater Labor (Diagnostic and Repair)	13	\$80.00			\$1,040.00

Estimate Summary:

Labor Hours	Labor Cost	Material Cost	Equipment	Total Cost	CE Factor	Total Estimate
13	\$1,040.00	\$2,952.77	\$0.00	\$3,992.77	103%	\$4,112.55



WORK ESTIMATE

CSS #:

26351

Work Order #:

10242

Emergency

Urgent

X

Routine

Company Name:	Tidewater, Inc.	Facility ID:	NY127
Contractor POC:	Adam Colopy		
Telephone No:	740-819-6207	Building/Location; (e.g., Classroom/Room #)	Mech
E-Mail Address:	adam.colopy@tideh2o.net		
Assigned Technician(s):	Patrick Brown		

DESCRIPTION of WORK and EXPLANATION for REPAIRS or REPLACEMENT

Labor and materials to replace hot water pump HWP-2-T. Note 4 week lead time for pump.

LABOR/MATERIAL		MATERIAL/ SUB UNIT DOLLAR AMOUNT	LBR/HR \$80	LINE ITEM TOTAL DOLLAR AMOUNT
ITEM	QUANTITY			
Labor			8	\$640.00
Armstrong Pump ASG4280	1	\$2,702.87		\$2,702.87
Freight Shipping	1	\$250.00		\$250.00
Diagnostic Labor			5	\$400.00
SUB-TOTAL COSTS:		Materials Total	\$2,952.87	Labor \$1,040.00
			TOTAL	\$3,992.87

F.W. Webb Company
6792 Townline Road
Syracuse, NY 13211
TEL# (315-476-9322)
FAX# (315-472-4139)

Quote
Number
66843782

To:
TIDEWATER, INC.
6625 SELNICK DRIVE

ELKRIDGE MD 21075

SAME
6792 Townline Road

SYRACUSE, NY 13211

(410-540-8700) Fax# (410-579-1685)

Cust #	Customer Po#	Rel#	Writer	Date Req
198314	ARMSTRONG PUMP		BTW	08/28/20

PAGE 1 OF 1

Quoted By: BRIAN WOLFORD

Quantity	Description	Net Price	Exten	Ln#
1	#ARMSTRONG CIRC PUMP 3HP 3P + ASG42802X1X104P (S3873215) 4 WEEKS ARO PLUS FRT	2111.620	2111.62	(1)
		Sub Total:	2111.62	
		Total:	2111.62	

*** NUMBER OF DAYS QUOTE VALID IS 10 ***

PLEASE REFERENCE QUOTE # 66843782 FOR INQUIRIES OR ORDER OF ABOVE MATERIAL

+ THIS PRODUCT IS A SPECIAL ITEM. RESTOCKING FEES MAY APPLY.

ARMSTRONG

**MODEL NO.**

2X1X10 4280

CONSTRUCTION

BF-STD

PUMP CAPACITY43 US
gpm

35 ft

C 745134

SERIAL NO.**MOTOR**

3 hp 1800 rpm

175 psi 250 °F

MAX. PRESS.**MAX. TEMP.****MOTOR**

30 Hz

HWP-2 T REV

TAGARMSTRONG PUMPS INC.
NORTH TONAWANDA, N.Y.
406912-100S.A. ARMSTRONG LIMITED
TORONTO, ONTARIO

www.armstrongpumps.com

Product of Canada