

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: V.A.006

Date of Visit: 2-22-21

Contractor Personnel on Site:

1. Cory Sandlin
2. _____
3. _____

4. _____
5. _____
6. _____

Service Call Number

CSS# 26700 WO# 12775

Description of Repairs

Found middle toilet leaking from wax seal. pulled toilet off of the wall. put new wax seal on. reinstated toilet. toilet is flushing fine with no leaks.

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Cory Sandlin Date: 2-22-21

Signed: Cory Sandlin

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SFC Jamie Watson Date: 2021/02/22

Signed: (ES) 2

E-Mail:



