

Additional Funding Request

NY051	CSS# 27203 WO# 10671 Asset# NA						
Description of Repairs	Will replace hot water pump#2						
Diagnosis: Initial Work Order	Repair hot water pump #2. Pump doesn't run						
Diagnostic Fee	\$ 240 \$80/hr. x 3						
Additional Labor Cost to Perform Repairs	\$ 640 \$80/hr. x 8						
Additional Material Cost to Perform Repairs	\$ 1591.24 <table border="1" style="width: 100%; border-collapse: collapse; margin-top: 5px;"> <tr> <td style="width: 50%;">B&G Pump SER# S3984685</td> <td style="width: 10%; text-align: center;">1</td> <td style="width: 20%; text-align: right;">\$1591.24</td> <td style="width: 20%; text-align: right;">\$1591.24</td> </tr> </table>			B&G Pump SER# S3984685	1	\$1591.24	\$1591.24
B&G Pump SER# S3984685	1	\$1591.24	\$1591.24				
Total Cost of Repair	\$ 2,471.24						



WORK ESTIMATE

CSS #: 27203

Work Order #: 10671

Emergency ☐ Urgent ☒

Routine ☐

Company Name:	Tidewater, Inc.	Facility ID:	NY051
Contractor POC:	Adam Colopy		
Telephone No:	740-819-6207	Building/Location; (e.g., Classroom/Room #)	
E-Mail Address:	adam.colopy@tideh2o.net		
Assigned Technician(s):	Patrick Brown		

DESCRIPTION of WORK and EXPLANATION for REPAIRS or REPLACEMENT

Repair hot water pump #2. Pump doesn't run

LABOR/MATERIAL		MATERIAL/ SUB UNIT DOLLAR AMOUNT	LBR/HR \$80	LINE ITEM TOTAL DOLLAR AMOUNT
ITEM	QUANTITY			
Diagostic			3	\$240.00
B&G Pump SER# S3984685	1	\$1,591.24		\$1,591.24
Labor			8	\$640.00
SUB-TOTAL COSTS:		Materials Total	\$1,591.24	Labor \$880.00
TOTAL			\$2,471.24	

F.W. Webb Company
6792 Townline Road
Syracuse, NY 13211
TEL# (315-476-9322)
FAX# (315-472-4139)

Quote
Number
Date
10/22/20 69082628

To:
TIDEWATER, INC.
6625 SELNICK DRIVE

SAME
6792 Townline Road

ELKRIDGE MD 21075

SYRACUSE, NY 13211

(410-540-8700) Fax# (410-579-1685)

Cust #	Customer Po#	Rel#	Writer	Date Req
198314	B&G PUMP PAT BROWN 31		BTW	10/22/20

PAGE 1 OF 1

Quoted By: BRIAN WOLFORD

Quantity	Description	Net Price	Exten	Ln#
1	#E-60 2 X6.25 BF 3/4HP 1800 + B/GE-602X6.2575BF (S3984685) 4 TO 5 WEEKA ARO	1326.030	1326.03	(1)

Sub Total: 1326.03
Total: 1326.03

*** NUMBER OF DAYS QUOTE VALID IS 10 ***

PLEASE REFERENCE QUOTE # 69082628 FOR INQUIRIES OR ORDER OF ABOVE MATERIAL

+ THIS PRODUCT IS A SPECIAL ITEM. RESTOCKING FEES MAY APPLY.

	BELL & GOSSETT	60	PUMP
SIZE	2X6-1/4 5.000 BF		
PUMP CAP.	GPM	FT	
MOTOR CAP.	7.5 HP 1800 RPM		
SERIAL NO.	2348105C40		CSA ENCL 2 

FOR THIS
PUMP

