

CERTIFICATION OF WORK
SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: VA011

Date of Visit: 12-6-20

Contractor Personnel on Site:

1. Moore
2. Paul Markham
3. _____
4. _____
5. _____
6. _____

Service Call Number

CSS# 27507

WO# _____

Description of Repairs

Found glycol leak at the inlet side. Fixed.
Found R22 leak on low side valve core. Replaced and
got unit back up on line.

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Paul Markham Date: 12-10-20

Signed: Paul Markham

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Chris Phillips Date: 12/9/20

Signed: Chris Phillips

E-Mail: _____