

CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: DE 07

Date of Visit: 1-22-21

Contractor Personnel on Site:

1. Brian Davis

4. _____

2. _____

5. _____

3. _____

6. _____

Service Calls – Service Call Number and Description

1. 13437 - Replaced blank

2. _____

3. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Brian Davis Date: 1-22-21

Signed: Brian Davis

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Danielle Bennett Date: 1-22-21

Signed: Danielle Bennett

E-Mail: _____

This Boiler is a Direct Vent Boiler for
Installations on Non-Combustible Floors Only

Fulton Gas Fired Pulse Combustion Boiler

Type of Gas: Natural Propane

Boiler Model No. PHW-1000

Boiler National Board No. 109874

Year 2010

Min. BTU Input/Hr. 200K Min. BTU Output/Hr. 180K

Max. BTU Input/Hr. 1000K Max. BTU Output/Hr. 900K

Design Pressure 160 PSI

Minimum Relief Valve Capacity: 900 Pounds/Hr.

Manifold Gas Pressure: 5.0 Inches W.C.

Maximum Gas Supply Pressure: 14 Inches W.C.

Minimum Permissible Gas Supply Pressure for Purpose of
Input Adjustment: 7 Inches W.C. 11 Inches W.C.

Electrical Ratings: 120 V/60 Hz/Less than 15 Amps

Low Pressure Steam and Hot Water Boiler

ANSI Z21.13 • CSA 4.9

High Pressure Steam Boiler

AGA Requirements 3-89

Wall Thickness Through Which Vent System May

Be Installed: 3 1/4 Inches Min. / 20 Inches Max.

Minimum Clearance to Combustibles:

1 inch (Sides) / 24 inches (Top, Front & Rear)



Fulton

Manufactured by
Fulton Heating Solutions, Inc.
Rome, New York 13442