

**CERTIFICATION OF WORK  
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: VA 099

Date of Visit: 8-18-22

Contractor Personnel on Site:

1. Chris Saunders
2. \_\_\_\_\_
3. \_\_\_\_\_
4. \_\_\_\_\_
5. \_\_\_\_\_
6. \_\_\_\_\_

**Service Call Number**

CSS# \_\_\_\_\_ WO# 17331

**Description of Repairs**

INSTALLED SAFETY VALVE ON DOMESTIC HOT WATER  
BOILER IN MECHANICAL ROOM 110

**CERTIFICATION OF WORK**

To be signed by the Contractor:

Print Name: Chris Saunders Date: 8-18-22

Signed: Chris Saunders

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Richard Murphy, SFC Date: 20220818

Signed: Richard Murphy

E-Mail: richard.b.murphy.16.m@army.mil



