

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: VSARC VA 049 Date of Visit: 05/03/21

Contractor Personnel on Site:

- | | |
|--------------------------|----------|
| 1. <u>Brandon Curtis</u> | 4. _____ |
| 2. <u>Cory Sandlin</u> | 5. _____ |
| 3. <u>Mike A</u> | 6. _____ |

Service Call Number

CSS# 28909 WO# 13644


Description of Repairs

Installed filter on hot return and supply
as well a filter on chiller water return and
supply tested for leaks - Job is complete.

CERTIFICATION OF WORK

To be signed by the Contractor:


Print Name: Brandon Curtis Date: 05/03/21

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Kenneth D Ross SFC Date: 3 May 2021

Signed: 

E-Mail: Kenneth.d.Ross.mil@mail.mil



