

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: VA-701 Date of Visit: 3/15/21

Contractor Personnel on Site:

1. Bond Water
2. _____
3. _____
4. _____
5. _____
6. _____

Service Call Number

CSS# _____ WO# _____

Description of Repairs

Added treatment to chll water glycol loop
to ensure glycol does not break down. This will
also maximize corrosion protection

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Jon Miller Date: 3/15/21
Signed: JM

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Terry Casey / SFC Date: 15 Mar 2021
Signed: TC
E-Mail: _____

