

## CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: V A 099

Date of Visit: 3/9/21

Contractor Personnel on Site:

1. Peter Langston
2. \_\_\_\_\_
3. \_\_\_\_\_
4. \_\_\_\_\_
5. \_\_\_\_\_
6. \_\_\_\_\_

**Service Call Number**

CSS# 29372 WO# 13869

### Description of Repairs

Call was for no heat in Motor Pool. Turned t-set up for service bays and heat came on. Let heat run no issues found with Infrad heater. Checked the mono-split cycled that unit on heat & AC. No issues found with mono-split

---

## CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Peter Langston Date: 3/9/21

Signed: Peter Langston

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Carlos M. Nieves Date: 3/9/21

Signed: Carlos M. Nieves

E-Mail: rodriguez.c.nieves.civ@mail.mil