

Additional Funding Request

MD002	CSS# 29428 WO# 13885 Asset# NA							
Description of Repairs	Labor and material to replace 3 emergency lights in building 3. Note: Only 3 fixtures in building & found no issues with exit lights upon investigating.							
Diagnosis: Initial Work Order	Repair 4x exit signs, and 4x emergency pathway lights, bldg 003.							
Diagnostic Fee	\$ 160 Labor \$80/hr x 2							
Additional Labor Cost to Perform Repairs	\$ 320 Labor \$80/hr x 4							
Additional Material Cost to Perform Repairs	\$ 189.44 <table border="1"><tr><td>Hubbell Light- Compass 120/277V LED Emergency Light</td><td>3</td><td>189.44</td><td>568.32</td></tr></table>				Hubbell Light- Compass 120/277V LED Emergency Light	3	189.44	568.32
Hubbell Light- Compass 120/277V LED Emergency Light	3	189.44	568.32					
Total Cost of Repair	\$ 1048.32							



WORK ESTIMATE

CSS #:

29428

Work Order #:

13885

Emergency

Urgent

Routine

X

Company Name:	Tidewater, Inc.	Facility ID:	MD002
Contractor POC:	Adam Colopy		
Telephone No:	740-819-6207	Building/Location; (e.g., Classroom/Room #)	
E-Mail Address:	adam.colopy@tideh2o.net		
Assigned Technician(s):	John Brown		

DESCRIPTION of WORK and EXPLANATION for REPAIRS or REPLACEMENT

Labor and material to replace 3 emergency lights in building 3. Note: Only 3 fixtures in building & found no issues with exit lights.

LABOR/MATERIAL		MATERIAL/SUB UNIT DOLLAR AMOUNT	LBR/HR \$80	LINE ITEM TOTAL DOLLAR AMOUNT
ITEM	QUANTITY			
Diagostic			2	\$160.00
Hubbell Lighting- Compass 120/277V LED Emergency Light	3	\$189.44		\$568.32
Labor			4	\$320.00
SUB-TOTAL COSTS:		Materials Total	\$568.32	Labor \$480.00
TOTAL			\$1,048.32	

< Back

Details



Tap image to Zoom



HUBBELL LIGHTING - COMPASS
120/277V LED Emergency Light, 1.9
WW, Gray Plastic, Nickel Cadmium
Battery Chemistry

Item # **32WU53** Mfr. Model # **CU2WG**
UNSCSP... Catalog Group # **32WU53**
Catalog Page # **424**

Your Price

\$150.35 / each

Home



Cart



Account



Branches



More

RIGHT TO KNOW CENTER

**MATERIAL SAFETY
DATA SHEETS FOR
HAZARDOUS MATERIALS
USED IN THIS AREA**

