

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: VA701 Date of Visit: 5-25-21

Contractor Personnel on Site:

1. Jacob Long
2. _____
3. _____
4. _____
5. _____
6. _____

Service Call Number

CSS# 29788 WO# 13968

Description of Repairs

Replaced defective water flow switch, purged air from water lines to confirmed switch operation

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Jacob Long Date: 5-25-21

Signed: [Signature]

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SFC Terry Casey Date: 25 MAY 2021

Signed: [Signature]

E-Mail: terry.l.casey.mil@mail.mil